

Local energy planning for commercial areas: what role for the Energy Efficiency First principle?

Tim Mandel, Fraunhofer ISI

13 April 2022



MAKING THE ENERGY EFFICIENCY FIRST PRINCIPLE OPERATIONAL



Agenda



01 | Background

Why is there a need for model-based assessments on commercial areas in the EU?



02 | Methodology

Scenarios, model, input data



Q&A Session



03 | Results

Building retrofits do pay off, but there are limitations




04 | Discussion

Why the results should be interpreted with caution

Background



Why is there a need for model-based assessments on commercial areas in the EU?



What's the objective of this case study?

Objective

Explore trade-offs and synergies between building retrofits and energy supply options in commercial areas

Key characteristics

- One archetypical commercial area in three EU countries
- Inspired by real-life buildings and topography
- Use of open-source modelling software for analysing system technology configurations and their cost-effectiveness
- Hourly resolution of system operation




Methodology

The background of the slide features a close-up, slightly blurred photograph of a study desk. On the left, a portion of a green notebook is visible. To its right is an open, aged book with yellowed pages. The pages of the book contain handwritten mathematical notes in a cursive script, including logarithmic identities such as $\log a^x = x \log a$ and $\log \frac{a}{b} = \log a - \log b$. Below the book, a black fountain pen with a silver nib and clip lies diagonally across a sheet of white graph paper with a light blue grid. The overall lighting is soft and even, creating a scholarly and focused atmosphere.


enefirst.

One archetype office park is examined in all three countries






No.	Type	Conditioned floor area (m ² %)	Gross floor area (m ² %)
#1	Office	25948 m ² 24.2%	37972 m ² 23%
#2	Lab	11955 m ² 11.2%	19438 m ² 11.8%
#3	Office	8653 m ² 8.1%	14070 m ² 8.5%
#4	School	6647 m ² 6.2%	10808 m ² 6.5%
#5	Canteen	6571 m ² 6.1%	10017 m ² 6.1%
#6	Office	4878 m ² 4.6%	6798 m ² 4.1%
#7	Office	4876 m ² 4.5%	6795 m ² 4.1%
#8	Office	4456 m ² 4.2%	6793 m ² 4.1%
#9	Office	4855 m ² 4.5%	6767 m ² 4.1%
#10	Office	4327 m ² 4%	6596 m ² 4%
#11	Office	4212 m ² 3.9%	6420 m ² 3.9%
#12	Office	3209 m ² 3%	5870 m ² 3.6%
#13	Office	3259 m ² 3%	5299 m ² 3.2%
#14	Office	2690 m ² 2.5%	4375 m ² 2.6%
#15	Office	2655 m ² 2.5%	4317 m ² 2.6%
#16	Office	2606 m ² 2.4%	4237 m ² 2.6%
#17	Office	1758 m ² 1.6%	2859 m ² 1.7%
#18	Office	1060 m ² 1%	1723 m ² 1%
#19	Office	888 m ² 0.8%	1444 m ² 0.9%
#20	Server room	844 m ² 0.8%	1373 m ² 0.8%
#21	Office	839 m ² 0.8%	1364 m ² 0.8%
		107186 m ² 100%	165337 m ² 100%


We consider buildings in three climate zones



The following scenarios are defined

Retrofit measures by building component U-value					
Scenario	Roof	Wall	Floor	Windows	
 DE	DE_Existing	Concrete ceiling with 5 cm insulation 0.51 W/(m²K)	Concrete panels 1.10 W/(m²K)	Concrete base with 2 cm insulation 0.77 W/(m²K)	Plastic frame with double glazing 3.00 W/(m²K)
	DE_Standard	+12 cm insulation 0.19 W/(m²K)	+12 cm insulation 0.23 W/(m²K)	+8cm insulation 0.28 W/(m²K)	Double glazing, argon filled, low emissivity 1.30 W/(m²K)
	DE_Advanced	+30 cm insulation 0.09 W/(m²K)	+24 cm insulation 0.13 W/(m²K)	+12 cm insulation 0.21 W/(m²K)	Triple glazing, argon filled, low emissivity 0.80 W/(m²K)
	ES_Existing	Wooden joints 1.92 W/(m²K)	Cavity wall 1.33 W/(m²K)	Wooden joints 1.13 W/(m²K)	Single glazing 5.70 W/(m²K)
 ES	ES_Standard	+2 cm insulation and gravel 0.60 W/(m²K)	+3 cm insulation 0.64 W/(m²K)	No improvement 1.13 W/(m²K)	Double glazing 1.84 W/(m²K)
	ES_Advanced	+6 cm insulation and greenery 0.15 W/(m²K)	+5 cm insulation 0.42 W/(m²K)	No improvement 1.13 W/(m²K)	Triple glazing 0.80 W/(m²K)
	HU_Existing	Concrete ceiling 0.44 W/(m²K)	Concrete panels 0.70 W/(m²K)	Concrete base 0.48 W/(m²K)	Wooden frame with double glazing 2.50 W/(m²K)
 HU	HU_Standard	+10 cm insulation 0.21 W/(m²K)	+5 cm insulation 0.37 W/(m²K)	+10 cm insulation 0.24 W/(m²K)	Double glazing, argon filled, low emissivity 1.60 W/(m²K)
	HU_Advanced	+24 cm insulation 0.12 W/(m²K)	+16 cm insulation 0.18 W/(m²K)	+20 cm insulation 0.16 W/(m²K)	Triple glazing, argon filled, low emissivity 1.00 W/(m²K)

The City Energy Analyst (CEA) tool is used to model the scenarios



©2021 The A/S group - ETH Zurich

Key features



Data helper



Urban solar radiation



Renewable energy assessment



Dynamic demand forecast



Multi-objective optimisation



Mapping & visualisation

Input data is compiled from various sources

Input data	Source
Building properties	TABULA project
Building retrofit cost	ENTRANZE project
Weather	Meteostat.net
Technology cost	RES-H project; DEA Technology Catalogue
Energy carrier prices	Eurostat; ENEFIRST project
GHG emission intensities	ENEFIRST project






Q&A Session

Results



Final energy demand



Final energy demand by end-use in DE [MWh/a]


Results

- Building retrofits reduce space heating demand by -59.2% (*DE_Standard*) and -72.3% (*DE_Advanced*)
- Space cooling demand slightly increases due to internal gains

Key message

According to the bottom-up model, thermal retrofits lead to significant reductions in final energy demand for buildings

District load curve



Load curve by end-use [MWh/d]

Results

- Peak load on 20 Feb with outdoor temperature of -4.5°C
- Peak load reduced from 138.2 (*DE_Existing*) to 82.0 (*DE_Standard*) and 70.9 MWh/d (*DE_Advanced*)

Key message

Building retrofits reduce peak demand and thus the capacities needed on the supply side

District heating network layout



District heating network layout at nominal operating conditions


Results

- CEA model computes potential layout of network with minimum spanning tree
- trench length 0.7–103.5 [m]
- mass flow rate 3.3–96.3 [kg/s]
- peak velocity 1.8–2.5 [m/s]

Key message

According to the simulation, a thermal hydraulic network is technically feasible for all buildings in the area

Solar generation potentials



Technical generation potentials for solar technologies [MWh/h]


Results

- Total space available (roofs) = 24,487 m² (= 156 x 156 m)
- Solar radiation = 24,263 MWh/a
- Technical potential = 3,301 (photovoltaics); 6,469 (solar thermal) MWh/a

Key message

Different technically viable solar technologies compete for limited roof space in the neighbourhood

Possible supply system configurations



Comparison of Pareto-frontiers for supply configurations [m EUR₂₀₂₀/a vs. tCO₂-eq/a]


Results

- Vertically: higher levels of GHG reduction for same level of cost
- Horizontally: reduced cost for same level of GHG reduction
- GHG 574.6 – 2,074.7 tCO₂-eq/a
- Cost 2.9 – 5.6 m EUR₂₀₂₀/a

Key message

In each scenario, buildings can be supplied by a variety of technically feasible technology configurations.

Heat dispatch



Results

- Base load covered by biomass CHPs; peaks served by natural gas boilers
- Peak thermal load reduces by -49.5% (DE_Standard) and -73.4% (DE_Advanced)


Key message

Building retrofits reduce district heating peak load and alter the composition of cost-effective technologies

Dispatch curve for heating plants on 20 Feb 2022

Thermal ET = Evacuated tube solar thermal collector; PVT Hybrid = Photovoltaic-thermal panel

Electrical dispatch & load



Results


- Peak electrical load reduces by -25.7% in DE_Standard and DE_Advanced
- Stable load for appliances (2.6 MWh/h)
- Var. load for DH network pumps (0.22–0.08 MWh/h)

Key message

Building retrofits do not only reduce thermal load in district heating networks, but also electrical load

Dispatch curve for electricity generators and load on 20 Feb 2022

Installed capacities



Results

- Heat generation capacity reduces by 37.5% (DE_Standard) and 48.4% (DE_Advanced)
- Onsite natural gas boilers significant technology in DE_Advanced (3.5 MW)
- DE_Standard not cost-effective

Key message

An advanced building retrofit is the most cost-effective option for meeting local energy demand while reaching equivalent GHG reductions

Installed heat generation capacities by technology [MW]

Discussion of the model-based results




Three reasons why the results should be interpreted with caution



Parameter uncertainties

- ☐ Learning rates & technology cost
- ☐ Energy carrier prices
- ☐ Climate conditions
- ☐ ...



Model capabilities

- ☐ No power network modelling
- ☐ No direct rebound effects
- ☐ No demand response



Cost/benefit accounting

- ☐ Search & information cost
- ☐ Comfort gains
- ☐ Reduced air pollution
- ☐ Real estate value
- ☐ Local employment
- ☐ ...



Key findings

- **Local planning for low-carbon energy systems involves a trade-off between saving and supplying energy.** Building retrofits reduce the magnitude of energy needed, thus also the generation capacities and the overall cost for energy supply. However, retrofits involve significant capital expenditures.
- **There is clear scope for Energy Efficiency First in local energy planning for commercial areas.** Deep renovations can be more cost-efficient in meeting equivalent greenhouse gas reductions than light renovations or strategies focusing exclusively on supply side investment.
- **Energy Efficiency First should not be equated with end-use energy efficiency.** Heat pumps, cogeneration and efficient district heating overall are a key requirement for achieving significant greenhouse gas reductions in commercial areas. Supply-side energy efficiency is key.
- **As with every model-based analysis, these results should be taken with caution.** The problem is not only uncertainties, but also the capabilities of the model setup as well as conceptual issues in counting costs and benefits.

Coming up in enefirst...



D3.3 | Is there need for the Energy Efficiency First principle in the European building sector and its energy supply?

D3.4 | What's the role of Multiple Impacts in implementing the Energy Efficiency First principle?

D3.5 | How does the Energy Efficiency First principle perform in a local context?



Q&A Session